

## HAZARDOUS SUBSTANCES RISK ASSESSMENT

### Designer Contracts Ltd

Unit 8, Church View, Coney Green, Chesterfield, S45 9HA

<b>CPL Stopgap 1200 Pro (Fball) Part A</b>	<b>Date of Assessment :</b> 05/06/2024	<b>Reference :</b> CPL - Stopgap 1200 Pro (Fball) Part A
<b>Risk Assessor :</b> Laura Cross	<b>Risk Assessor :</b>	
<b>Other People Involved in Making This Assessment :</b> Antony Maidens		



<b>R or H Descriptors:</b>	<b>S or P Descriptors:</b>
H317 May cause an allergic skin reaction H319 Causes serious eye irritation	P280 Wear protective gloves/protective clothing/eye protection/face protection P302+352 IF ON SKIN; Wash with soap and water P305+351+338 IF IN EYES; Rinse cautiously with water for several minutes. Remove contact lenses if present and easy to do - continue rinsing P501 Dispose of contents/container to ...xxxxx P261 Avoid breathing dust/fume/gas/mist/vapours/spray P308+313 IF exposed or concerned; Get medical advice/attention
<b>Additional Information</b> P501 Dispose of contents/ container in accordance with national regulations.	
<b>Workspace Exposure Limit (WEL)</b> WEL (8h) 4 mg/m <sup>3</sup>	

<b>Primary route(s) of entry :</b> Absorption, Ingestion, Inhalation	
<b>This is a Group C Substance.</b>	<b>The quantity used per batch or work period is: Medium (1-1000kg or 1-1000L)</b>
<b>The Substance is a Solid of High dustiness</b>	
<b>Containment is the control measure appropriate to control the health risks from the use of this substance. Health Surveillance is not required.</b>	

<b>Existing Control Measures</b>
1. Always Use in a well ventilated area.
2. Description of first aid measures: By inhalation: This product is not classified as hazardous through inhalation. However, in case of intoxication symptoms it is recommended to remove the person affected from the area of exposure, provide clean air and keep at rest.

3. By skin contact: May cause an allergic skin reaction. In case of contact it is recommended to clean the affected area thoroughly with water and neutral soap. In case of changes on the skin (stinging, redness, rashes, blisters,...), seek medical advice with this Safety Data Sheet
4. By eye contact: Rinse eyes thoroughly with lukewarm water for at least 15 minutes. Do not allow the person affected to rub or close their eyes. If the injured person uses contact lenses, these should be removed unless they are stuck to the eyes, in which case this could cause further damage.
5. In all cases, after cleaning, a doctor should be consulted as quickly as possible with the SDS of the product.
6. By ingestion/aspiration: Do not induce vomiting, but if it does happen keep the head down to avoid aspiration. Keep the person affected at rest. Rinse out the mouth and throat, as they may have been affected during ingestion.
7. Suitable extinguishing media: Product is non-flammable under normal conditions of storage, handling and use. In the case of combustion as a result of improper handling, storage or use preferably use polyvalent powder extinguishers (ABC powder),
8. Unsuitable extinguishing media: Non-applicable
9. ACCIDENTAL RELEASE MEASURES For non-emergency personnel: Sweep up and shovel product or collect by other means and place in container for reuse (preferred) or disposal For emergency responders: Wear protective equipment. Keep unprotected persons away
10. Environmental precautions: This product is not classified as hazardous to the environment. Keep product away from drains, surface and ground water.
11. Methods and material for containment and cleaning up: It is recommended: Sweep up and shovel product or collect by other means and place in container for reuse (preferred) or disposal
12. Technical recommendations on general occupational hygiene Do not eat or drink during the process, washing hands afterwards with suitable cleaning products.
13. Technical recommendations to prevent environmental risks It is recommended to have absorbent material available at close proximity to the product
14. Technical measures for storage Minimum Temp.: 5 °C Maximum Temp.: 30 °C Maximum time: 6 Months
15. General conditions for storage Avoid sources of heat, radiation, static electricity and contact with food. For additional information see subsection 10.5 Keep the container tightly sealed and protected from open air and humidity
16. Compulsory use of face mask Filter mask for particles Replace when an increase in resistance to breathing is observed.
17. Mandatory hand protection Chemical protective gloves Replace the gloves at any sign of deterioration.
18. Mandatory face protection Panoramic glasses against splash/projections. Clean daily and disinfect periodically according to the manufacturer's instructions. Use if there is a risk of splashing.
19. Emergency shower ANSI Z358-1 ISO 3864-1:2011, ISO 3864-4:2011 Eyewash stations DIN 12 899 ISO 3864-1:2011, ISO 3864-4:2011
20. Disposal methods Code 16 03 03\* Description inorganic wastes containing hazardous substances Waste class Non dangerous
21. Product - Cement that has exceeded its shelf life: 10 13 99 Product - Unused residue or dry spillage: 10 13 06 Product - after addition of water, hardened: 10 13 14, 17 01 0
22. All empty packaging should be returned to region and disposed of in Drum B

**Documents Associated with this Risk Assessment :** Stopgap-1200-Pro-Powder-iss-7.pdf(safety data sheet) Stopgap-1200-Pro-Powder-iss-6-1.pdf(SDS) Stopgap-1200-Pro-Powder-iss-8.pdf(SDS)

**Review Date :** 09/06/2025