

## HAZARDOUS SUBSTANCES RISK ASSESSMENT

### Designer Contracts Ltd

Unit 8, Church View, Coney Green, Chesterfield, S45 9HA

<b>CPL - Stopgap P131 Primer (FBall)</b>	<b>Date of Assessment :</b> 03/06/2024	<b>Reference :</b> CPL - Stopgap P131 Primer (FBall)
<b>Risk Assessor :</b> Laura Cross	<b>Risk Assessor :</b>	
<b>Other People Involved in Making This Assessment :</b> Antony Maidens		

<b>R or H Descriptors:</b>	<b>S or P Descriptors:</b>
<b>Additional Information</b>	
<b>Workspace Exposure Limit (WEL)</b> No WEL stated on SDS	

<b>Primary route(s) of entry :</b> Absorption, Ingestion, Inhalation	
<b>This is a Group Substance.</b>	<b>The quantity used per batch or work period is:</b> Medium (1-1000kg or 1-1000L)
<b>The Substance is a Liquid of Low volatility</b>	
<b>is the control measure appropriate to control the health risks from the use of this substance. Health Surveillance is not required.</b>	

<b>Existing Control Measures</b>
1. First aid measures:By inhalation: This product does not contain substances classified as hazardous for inhalation, however, in case of symptoms of intoxication remove the person affected from the exposure area and provide with fresh air. Seek medical attention if the symptoms get worse or persist.
2. By skin contact: In case of contact it is recommended to clean the affected area thoroughly with water and neutral soap. In case of changes to the skin (stinging, redness, rashes, blisters,...), seek medical advice with this Safety Data Sheet
3. eye contact: Rinse eyes thoroughly with water for at least 15 minutes. If the injured person uses contact lenses, these should be removed unless they are stuck to the eyes, in which case removal could cause further damage. In all cases, after cleaning,
4. By ingestion/aspiration: In case of consumption, seek immediate medical assistance showing the SDS for the product
5. Extinguishing media: Suitable extinguishing media: Product is non-flammable under normal conditions of storage, handling and use. In the case of combustion as a result of improper handling, storage or use preferably use polyvalent powder extinguishers (ABC powder),
6. ACCIDENTAL RELEASE MEASURES For non-emergency personnel: Isolate leaks provided that there is no additional risk for the people performing this task. Personal protection equipment must be used against potential contact with the spilt product
7. Environmental precautions: This product is not classified as hazardous to the environment. Keep product away from drains, surface and ground water.
8. HANDLING AND STORAGE Technical recommendations on general occupational hygiene Do not eat or drink during the process, washing hands afterwards with suitable cleaning products.

9. Conditions for safe storage, including any incompatibilities: A.- Technical measures for storage Minimum Temp.: 5 °C Maximum Temp.: 30 °C Maximum time: 6 Months B.- General conditions for storage Avoid sources of heat, radiation, static electricity and contact with food
10. Exposure controls Respiratory protection The use of protection equipment will be necessary if a mist forms or if the occupational exposure limits are exceeded.
11. Protective gloves against minor risks Replace gloves in case of any sign of damage. For prolonged periods of exposure to the product for professional users/industrials, we recommend using CE III gloves in line with standards EN 420:2004+A1:2010 and EN ISO 374-1:2016+A1:2018
12. Eye and face protection. Panoramic glasses against splash/projections. Clean daily and disinfect periodically according to the manufacturer's instructions. Use if there is a risk of splashing.
13. Emergency shower ANSI Z358-1 ISO 3864-1:2011, ISO 3864-4:2011 Eyewash stations DIN 12 899 ISO 3864-1:2011, ISO 3864-4:2011
14. Waste treatment methods: Description It is not possible to assign a specific code, as it depends on the intended use by the user. Waste class Non dangerous Take all empty containers back to region and dispose of in Drum B

**Documents Associated with this Risk Assessment :** Stopgap-P131-iss-11.pdf(SDS) Stopgap 131 Primer FBall SDS.pdf(SDS)

**Review Date :** 07/06/2025